EMERGENCY LIGHTING TEST LOG

If you have questions, discuss with inspector during inspection. Please do not return. For your records only.

THE FIRE PREVENTION CODE REQUIRES ALL EMERGENCY LIGHTING UNITS TO BE TESTED MONTHLY FOR A MINIMUM OF 30 SECONDS AND ANNUALLY FOR A MINIMUM OF ONE HOUR. RECORD THE LOCATION OF EACH EMERGENCY LIGHTING UNIT AND ILLUMINATED EXIT SIGN, THEN RECORD THE DURATION OF EACH TEST EVERY MONTH.

IF UNIT FAILS TO ILLUMINATE DURING TEST, HAVE UNIT REPAIRED IMMEDIATELY!

LIST LOCATION OF EMERGENCY LIGHT UNIT OR EXIT SIGN	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC